

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 871

Dated: 20/02/2026

It is certified that an inspection team headed by Es. Sakshi Negi (J.E.)

(Name of Officers with designation) from JSV Section Gaura PHED

inspected the Govt. Utkrishit Senior Secondary School Thakri


(Name & Address of the school) on 19-02-2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. BC/2025-26/1174 dated 20-02-2026

of Water Testing Laboratory JSV Rampur (PHED Lab) certified that the
Govt Utkrishit Sr. Sec. School Thakri (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.

This certificate is valid till 19-02-2027


Assistant Engineer
Jal Shakti Sub Division
Rampur

Signature with Seal:

Name : Bisbal Modi

Designation : Assistant Engineer

Name & Address of the Office / Department :

Jal Shakti Sub-Division
Rampur

To The Principal
Govt. Utkrishit Sr. Sec. School Thakri
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

WATER TESTING LABORATORY, RAMPUR

JAL SHAKTI SUB DIVISION RAMPUR, SHIMLA (H.P.)-172001

Lab Ref. No.: BC/2025-26/1174

Date: 20/02/2026

Name: Govt Utkrisht Senolor Secondary School Jhakri

Block : Rampur

Panchayat : Jhakri

Village/Habitation : Jhakri

Location:

Jhakri

Type of Source: Tap Water

Date of Collection:

19/02/2026

Date of Receipt at laboratory:

19/02/2026

Date of commencing:

19/02/2026

PHYSICAL EXAMINATION

S.No	Name of Parameters	Units	Acceptable Limit	Permissible Limit	Result
1	Color	Hazen	5	15	5.0
2	Odour	NA	Agreeable	Agreeable	Agreeable
3	Taste	NA	Agreeable	Agreeable	Agreeable
4	PH	NA	6.5 to 8.5	No Relaxation	7.32
5	TDS	Mg/L	500	2000	106.2
6	Turbidity	NTU	1	5	1.0


CHEMICAL EXAMINATION

S.No	Name of Parameters	Units	Acceptable Limit	Permissible Limit	Result
1	Total alkalinity	Mg/L	200	600	56
2	Chloride	Mg/L	250	1000	14
3	Total Hardness	Mg/L	200	600	104
4	Calcium	Mg/L	75	200	32.06
5	Magnesium	Mg/L	30	100	5.83
6	Iron	Mg/L	1.0	No Relaxation	0.0
7	Fluoride	Mg/L	1.0	1.5	0.0
8	Nitrate	Mg/L	45	No Relaxation	2.43
9	Residual Chlorine	Mg/L	0.2	1.0	0.0

BACTERIOLOGICAL EXAMINATION

S.No	Name of Parameters	Units	Acceptable Limit	Permissible Limit	Result
1	Total Coliform	CFU/100 ml	Shall not be detectable in any 100 ml sample	No relaxation	0


 Assistant Chemist
 Jal shakti Sub.Division
 Rampur


 Assistant Engineer
 Jal Shakti Sub.Division
 Rampur